

**Public Record – Summary Information on Underground Storage Tanks (USTs)
From 10/1/2012 To 9/30/2013 General Information**

Total Number of Active UST Facilities: 5,240
Total Number of Active UST compartments: 16,099

Summary Information For On-Site Inspections

Number of UST Facilities Inspected: 2,815
Inspection Period: 10/1/2012 To 9/30/2013
Percent Compliance
Release Prevention: 88.82%
Release Detection: 88.25%
Combined Compliance: 80.80%

Note: Tanks, facility, and on-site inspection information is based on underground storage tanks regulated under Subtitle I that satisfy the definition of UST in 40 CFR 280.12, except for those tanks identified in 40 CFR 280.10(b) as excluded USTs and those deferred in 40 CFR 280.10(c). On-site inspections measure compliance with release detection and release prevention (significant operational compliance, state regulations, Subtitle I, etc.).

Summary Information For Releases

Number of Confirmed UST Releases: 121
Release Reporting Period: 10/1/2012 To 9/30/2013

Summary Information For Release Sources and Causes

Source/Location			Cause															
			Not Listed		Spill		Overfill		Corrosion		Install Problems		Phys/Mech Damage		Unknown		Other	
	#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%
Not Listed	17	14.05%	16	59.26	0	0%	0	0%	0	0%	0	0%	0	0%	1	1.32%	0	0.00%
Delivery Problem	1	0.82%	0	0%	0	0%	1	100%	0	0%	0	0%	0	0%	0	0%	0	0.00%
Dispenser	4	3.31%	1	3.70%	0	0%	0	0%	0	0%	0	0%	3	21.42%	0	0%	0	0.00%
Other	6	4.96%	1	3.70%	1	100%	0	0%	0	0%	0	0%	2	14.29%	0	0%	2	100%
Overfill	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0.00%
Piping	13	10.74%	6	22.22%	0	0%	0	0%	0	0%	0	0%	7	50.00%	0	0%	0	0.00%
STR	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0.00%
Tank	7	5.79%	3	11.12%	0	0%	0	0%	0	0%	0	0%	2	14.29%	2	2.63	0	0.00%
Unknown	73	60.33%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	73	96.05%	0	0.00%
Total	121		27		1		1		0		0		14		76		2	

Note: Release, source and cause information is based on underground storage tanks regulated under Subtitle I that satisfy the definition of UST in 40 CFR 280.12. This report reflects data from releases reported to the Department during the time period of the report. Source and cause data were collected using on-site inspections and reports from facilities.

Additional information on site-specific USTs such as compliance and releases may be obtained through contacting the Tennessee Division of Underground Storage Tanks at 615-532-0945.